

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION  
OFFICE OF THE STATE FIRE MARSHAL  
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

# LISTING SERVICE

**LISTING No.** 7135-0078:185 Page 1 of 1

**CATEGORY:** Audible Devices

**LISTEE:** ADEMCO, 165 Eileen Way, Syosset, NY 11791  
Contact: Dave Kalmus (516) 921-6704

**DESIGN:** Models HS1215, HS2415, HS2475 and HS24110 horn/strobes with or without suffix -W (white color). Refer to listee's data sheet for additional detailed product description and operational considerations.

**RATING:**

Electrical:	HS12: 10.5 - 17 VDC
	HS24: 20 - 30 VDC
Candela:	-15: 15cd
	-1575: 15cd, 75cd on axis
	-75: 75cd
	-110: 110cd

**INSTALLATION:** In accordance with listee's printed installation instructions, applicable codes & ordinances and in a manner acceptable to the authority having jurisdiction. These sounder/strobe combination units are not intended for field assembly.

**MARKING:** Listee's name, model number, rating and UL label.

**APPROVAL:** Listed as horn strobes for use with separately listed compatible fire alarm control units. Suitable for the hearing impaired application. For wall mount and indoor use only.

\*Units can generate the distinctive three-pulse Temporal Pattern Fire Alarm Evacuation Signal (for total evacuation) in accordance with NFPA 72, 1993 Edition. Refer to manufacturer's Installation Manual for details.

**NOTE:** Models HS1215 is NOT intended for Public Mode Fire Alarm Service when used on 12 V control panel at low volume.

**XLF:** 7135-1209:173

\*Corrected 07-21-98



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued:

**JUNE 8, 2002**

*Listing Expires **June 30, 2003***

Authorized By:

**DIANE K. AREND**, Senior Deputy  
Program Manager